

J042-10450

ADDENDUM NUMBER 5

MILWAUKEE COUNTY CORRECTIONAL FACILITY
8885 South 68th Street
Franklin, WI 53132

SHOWER VENTILATION IMPROVEMENTS
RE-BID

Building #612

Site #295

Project No.: J042-10450

Contract 2: General Construction and Shower Ventilation

Date of Addendum: November 12, 2010

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated September 8, 2010, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

BIDDING, CONTRACT DOCUMENTS, ADDENDUM 1, 2,3 and 4

DRAWINGS


CHANGE the following:

MECHANICAL

Sheet M-5

1. ADD Detail on sheet M-5 and number as Detail 7. See attached Drawing SD-1. Supplemental Drawing SD-1 is attached to and issued as part of this Addendum 5.

End of Addendum No. 5




NOTES:

1. INSTALL MEDIUM SECURITY BARS AT OPENINGS. #8 REBAR LOCATED 6" ON CENTER VERTICALLY AND HORIZONTALLY. THE END REBAR TO BE EMBEDDED 8" ON EACH END.
2. BARS SHALL BE EPOXY COATED.
3. SEAL ALL DUCTS JOINTS WITH SILICONE SEALANTS.

7 Typical Duct Barred Opening Connection Detail

Scale: No Scale

Milwaukee County Correctional Facility
SHOWER VENTILATION IMPROVEMENTS
 8885 South 68th Street - Franklin, Wisconsin



MILWAUKEE COUNTY DEPARTMENT OF
 TRANSPORTATION AND PUBLIC WORKS
 CITY CAMPUS 301 W. WELLSTREET - 2ND FLOOR MILWAUKEE, WISCONSIN

REVISIONS

DATE
 11/12/2010
 PROJECT
 J042-10450
 SITE
 285
 BUILDING
 612

SD-1